



Office of the District Fire Officer, Hebbal Fire Station,
Karnataka Fire & Emergency Services,
Manyata Embassy Business Park, Nagawara Ring Road,
Bengaluru-560 045.



No.27/DFO/HBFS/2024

Dated: 21-03-2024.

ANNEXURE – B

Group - B Educational Building

To,
The Principal,
Shiksha Sagar High School,
No 04, KEB Layout, Sanjaynagar,
Bangalore-560094.
Sir,

Sub : Issue of "Fire Safety Compliance" with respect to fire prevention, fire fighting and evacuation measures required at "Shiksha Sagar high School", Situated at No 04, KEB Layout, Sanjaynagar, Bangalore-560094.

Ref : 1) Fire safety recommendation report No.331/CFO/BWZ/2020,
Dated:16-06-2020.
2) Your request letter dated: 16-03-2024.
3) FSO Hebbal Inspection report No.22/FSO/HBFS/2024,
Dated: 19-03-2024.

<<<<>>

With reference to the subject cited (1) above, a fire safety recommendation report was issued for "Shiksha Sagar High School", Situated at No 04, KEB Layout, Sanjaynagar, Bangalore-560094.


In your letter cited in reference (2) above, it is informed that all the recommendations stipulated in Fire safety recommendation has been fulfilled & hence requested to issue Fire safety compliance report. In this regard the building was inspected by Fire Station Officer, Hebbal on 19-03-2024 to check the compliance of all the recommendations stipulated in Fire safety recommendation & Submitted the Compliance report cited in reference (3) above & recommended to issue Compliance certificate.

Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing "Fire safety compliance report" to "Shiksha Sagar High School", Situated at No 04, KEB Layout, Sanjaynagar, Bangalore-560094. Subject to proper maintenance of fire fighting measures & fire fighting installations in good working condition, and to impart training for 40% of employees/staff in basic fire fighting at R.A Mundkur Fire & Emergency Services Academy, Bangalore within 90 days from the date of issue of this report. "This report is valid for one year from the date of issue up to 20-03-2025 and is renewable without fail."

Yours faithfully,


DISTRICT FIRE OFFICER 21/3/24
Hebbal Fire Station
Bengaluru - 560045


MANAGER
SHIKSHA SAGAR HIGH SCHOOL
AFFL. NO. 830462, SCHOOL CODE : 45373
4, KEB Layout, Sanjay Nagar, Bangalore-560094
E-mail : sshsppl14@gmail.com Mobile No.


PRINCIPAL
Shiksha Sagar High School
Affl. To CBSE, No:- 830462
4, KEB Layout, Sanjaynagar
Bangalore - 560 094